PB90-219700

Radon Mitigation in Schools: Case Studies of Radon Mitigation Systems Installed by EPA in Four Maryland Schools are Presented

(U.S.) Environmental Protection Agency, Research Triangle Park, NC

1990

U.S. Department of Commerce
National Technical Information Service
NTIS

AEERL-P-595

TECHNICAL REPORT DATA
(Please read Instructions on the reverse before complet

1. REPORT NO. EPA/600/J-90/010	2.	3. PB90-219700
4. TITLE AND SUBTITLE Radon Mitigation in Schools: Case Studies of Radon Mitigation Systems Installed by EPA in Four Maryland Schools Are Presented		5. REPORT DATE 6. PERFORMING ORGANIZATION CODE
7. AUTHOR(S) K. W. Leovic, A. B. Craig, and D. W. Saum* (part I); D. Saum, A. Craig, and K. Leovic (part II).		8. PERFORMING ORGANIZATION REPORT NO.
9. PERFORMING ORGANIZATION NAME AND ADDRESS (*) Infiltec P. O. Box 8007 Falls Church, Virginia 22011		10. PROGRAM ELEMENT NO. 11. CONTRACT/GRANT NO. (*)EPA POs 8D5032NASA and 8D2398NALX
12. SPONSORING AGENCY NAME AND ADDRESS **EPA, Office of Research and Development** Air and Energy Engineering Research Laboratory **Research Triangle Park, NC 27711**		13. TYPE OF REPORT AND PERIOD COVERED Journal article; 2/88-11/89 14. SPONSORING AGENCY CODE **EPA/600/13**

15. SUPPLEMENTARY NOTES AEERL project officer is Kelly W. Leovic, Mail Drop 54, 919/541-7717. ASHRAE J., Vol. 32, No. 2, pp. 20-25, February 1990. Part I was in ASHRAE J., Vol. 32, No. 1, pp. 40, 42, 44, and 45 (January 1990).

16. ABSTRACT

The first part of this two-part paper discusses radon entry into schools, radon mitigation approaches for schools, and school characteristics (e.g., heating, ventilation, and air-conditioning -- HVAC -- system design and operationg) that influence radon entry and mitigation system design. The second part discusses specific mitigation systems that were installed by the U.S. EPA in four Maryland schools. HVAC systems in schools vary considerably and tend to have a greater impact on pressure differentials -- and consequently on radon levels -- than do heating and air-conditioning systems in houses. If the HVAC system induces a negative pressure relative to the subslab area, radon can be "pulled" into the building. If the HVAC system pressurizes the building, it can prevent radon entry as long as the fan is running. However, school HVAC systems are normally set back or turned off on evenings and weekends and, even if the HVAC system pressurizes the school during operation, indoor radon levels may build up during the setback periods. The primary mode of radon entry into a school with significantly elevated radon levels is normally from soil gas that is drawn in by pressure differentials between the soil surrounding the substructure and the building interior.

17. KEY WORDS AND DOCUMENT ANALYSIS

a. DESCRIPTORS	b. IDENTIFIERS/OPEN ENDED TERMS	c. COSATI Field/Group
Pollution Soils	Pollution Control	13B 08G, 08M
Radon	Stationary Sources	07B
School Buildings	Soil Gas	13M, 05I
Air Conditioning	Indoor Air	13A
Ventilation		
Heating		

18. DISTRIBUTION STATEMENT **Release to Public**	19. SECURITY CLASS *(This Report)* **Unclassified**	21. NO. OF PAGES 7
	20. SECURITY CLASS *(This page)* **Unclassified**	22. PRICE A02

EPA Form 2220-1 (9-73)

REPRODUCED BY
U.S. DEPARTMENT OF COMMERCE
NATIONAL TECHNICAL INFORMATION SERVICE
SPRINGFIELD, VA. 22161

EPA/600/J-90/010

Radon mitigation in schools

Case studies of radon mitigation systems installed by EPA in four Maryland schools are presented

By David Saum, A.B. Craig and Kelly Leovic

NTIS is authorized to reproduce and sell this report. Permission for further reproduction must be obtained from the copyright owner.

Editor's Note: Part I of this article (which appeared in the January issue of the ASHRAE Journal) described radon entry into schools and the most common mitigation methods currently used. The article also discussed the school characteristics that influence radon entry and mitigation system design.

Since 1987, more than 40 schools in Maryland, Virginia, Tennessee and North Carolina were visited by the U.S. Environmental Protection Agency (EPA). School characteristics that potentially influence radon entry and impact mitigation system design and performance were identified. Mitigation systems that had proven successful in house mitigation were then installed in several of these schools. Many of the systems were installed by school personnel with some assistance from EPA and an experienced radon diagnostician.

About the authors

David Saum is the president and founder of Infiltec, Falls Church, Virginia. Saum received a B.S. in physics from the University of North Carolina and a M.S. in physics from the University of Wisconsin. He is the vice chairman of ASTM Subcommittee E06.41 on infiltration performance of buildings. He has co-authored papers on radon at ASHRAE IAQ '88 and IAQ '89.

A.B. Craig is the senior physical scientist-radon at the EPA's Air and Energy Engineering Research Laboratory in Research Triangle Park, North Carolina. Craig has overall responsibility for EPA's national radon mitigation research, development and demonstration program. Craig has a B.S. in chemistry from the University of Missouri and is a licensed contractor. He is the inventor of 30 U.S. patents and their foreign counterparts.

Kelly W. Leovic is an environmental engineer with the EPA's Radon Mitigation Branch in the Air and Energy Engineering Research Laboratory. She received a B.S. in geology and a M.S. in environmental engineering, both degrees from Duke University. She has given presentations on radon in schools at ASHRAE IAQ '88 and IAQ '89.

Based on the information obtained during this research, several conclusions can be made. First, the design and operation of a school's HVAC system can contribute significantly to elevated radon levels and also influences the type of mitigation system selected. Second, pressure control through continuous HVAC fan operation can be an effective, temporary solution to reduce radon levels in some circumstances.

Third, subslab depressurization systems similar to those used in houses can also be effective in schools provided certain on-site conditions exist. However, the subslab depressurization systems in schools typically require greater fan capacities and suction pipe diameters than house mitigation systems.

This article presents the diagnostic measurements made in the schools and it discusses in detail the specific mitigation systems that were installed in four Maryland schools by the EPA.

Data collection methodology

To assist in understanding radon entry into the schools and to design effective mitigation systems for the schools, continuous data were collected as part of the diagnostic measurements. A portable data monitoring system recorded Julian Day, hour, differential pressure (three sensors), and temperature (four sensors). Radon data were collected with a continuous radon monitor (CRM). There was no interface between the CRM and the data logger, and software was developed so that the CRM and data logger data could be merged in a computer for further analysis.

Hourly data averages were computed from sensor readings collected approximately every five seconds. This system allows for approximately two weeks of unattended data storage. Not all of the sensors were used during each experiment, and the positioning of sensors varied according to building size and configuration.

In addition to continuous data, five-minute radon grab samples were occasionally collected with the CRM during visits to the schools. Spot pressure differential measurements with a micromanometer were also made in a few cases when setup of the data logger was not possible. To determine the coverage of subslab depressurization systems, pressure field extension measurements were sometimes made. Test holes (measuring 0.25 in. in diameter) were drilled at various distances and in various directions from the suction holes, depending on building size and configuration. The resulting test hole pressures were measured with a micromanometer. Radon grab samples were occasionally collected through these test holes as well.

Case Study A

Radon levels in this school were initially measured in February 1988 with charcoal canisters. At that time, one classroom tested above 40 pCi/L, a teachers' lounge tested above 20 pCi/L, and several other classrooms tested between 4 and 20 pCi/L.

This building is slab-on-grade construction with a large two-fan air handling system. The HVAC system had a rated capacity of 51,000 cfm of air supply and 34,000 cfm of return air.

Louvers regulate the amount of fresh air and recycled air in the system. This would result in positive pressure in all rooms if the system were properly balanced. However, continuous radon and pressure measurements indicated that many rooms were under negative pressure relative to the subslab area when both the supply and return fans were in operation.

The room with the highest radon level (usually 10 to 20 pCi/L) typically measured between 0.06 and 0.08 in. WC negative pressure relative to the subslab. When the return air fan was turned off, the pressure in the room became positive and radon levels decreased to less than 2 pCi/L. Examination of the air-handling system showed that the air supply fan had been damaged, resulting in a significant capacity loss. As a result, the supply fan was actually supplying less air than the return air fan was removing, causing a negative pressure in many rooms.

This same room with the highest radon level and the highest negative pressure also had a very large floor-to-wall crack along one wall. This crack was an

expansion joint where two parts of the building were joined. The material in the expansion joint had disintegrated and the parts appeared to have separated, leaving a 1-in. gap between the floor and wall. This gap was concealed by an aluminum angle iron installed when the building was built.

When the return fan was operating, initial tests in this room showed a large flow of radon-containing soil gas out of this crack. The radon level was about 500 pCi/L in the soil gas entering the room through the crack, the same measured under the slab in the middle of the room.

When the return air fan was turned off and the room was pressurized by the air supply fan, room air flowed into the crack and, consequently, no soil gas entered. The pressure in the room relative to the subslab increased to about 0.01 in. WC and radon levels in the room quickly dropped below 2 pCi/L.

The floor-to-wall crack was sealed with backer rod and urethane caulking. This sealing decreased radon levels only slightly when both fans were off, indicating other soil gas entry points in the room.

The influence of HVAC operation on the pressure differential between this room and the subslab area and the resulting radon levels in the room are displayed in *Figure 1* for a seven-day period. (The return air louvers were closed during these measurements.) While the HVAC system is operating, the room is at a higher pressure than the subslab area and, consequently, radon entry is reduced. However, when the HVAC system is turned off during night and weekend setback, pressure in the room becomes negative relative to the subslab area and radon levels increase.

As a temporary solution to reduce radon levels, the return air fan was left off and the HVAC system operated with only the air supply fan. Under these conditions, all rooms showed positive pressure and had radon levels below 2 pCi/L during HVAC operation. The damaged supply fan has now been replaced and the air supply and air return systems are being balanced.

As a precaution to reduce radon entry when the air handlers are not operating during night or weekend setback, two fan-assisted subslab depressurization points have been installed. It is anticipated that this will be an effective mitigation system since the school was constructed on 4 in. of subslab aggregate. Follow-up testing was initiated during the 1988-89 heating season and will continue in the entire school during the 1989-90 heating season.



Figure 1. Influence of HVAC operation on pressure differential and radon level in Case Study A.

Case Study B

This is a small school built on the side of a hill with a walkout basement along the lower side. The unexcavated area is slab-on-grade with the slab extending over the basement area and resting on steel bar joists. The foundation walls are concrete block. The interior wall of the basement supports the end of the bar joists and the slab. This wall is not painted or waterproofed on either side. Building plans specify 4 in. of subslab aggregate.

The HVAC system consists of a single-fan system on each floor. A fresh air intake into the return air duct is under negative pressure during fan operation. Pressure measurements indicate that the building is under positive pressure even when the fresh air intake is set for minimum supply. However, since the HVAC system is normally set to run only when heating or cooling is required, the system may not operate during mild weather. In addition, the temperature in the below-grade part of the school is often buffered and, consequently, the basement HVAC system does not run as often as the upstairs system.

Radon levels in all rooms were measured with charcoal canisters over a weekend in May 1988 with the air handlers off. Measurements ranged from 78 to 82 pCi/L in the basement and from 18 to 33 pCi/L on the first floor. Subslab and block wall grab samples measured as high as 1,500 pCi/L.

Continuous radon measurements were made on both floors of the school during all phases of mitigation. Before mitigation, radon levels rose dramatically at night if the air handlers were off but did not rise during continuous operation. Pressure measurements indicated that operation of the air handlers produced a slight positive pressure in the building relative to the subslab area, thus reducing soil gas entry.

In the hottest part of the summer, radon levels rose dramatically overnight when the air handlers were off. It is suspected that a night stack effect resulted since the hot inside daytime temperatures did not decrease as rapidly at night as the outdoor temperature.

Overnight levels as high as 150 pCi/L were reached in the basement, and levels as high as 100 pCi/L were reached on the first floor when the air-handling fans were off during hot weather. Continuous operation of the HVAC system reduced radon levels to less than 4 pCi/L within an hour.

As a temporary solution, the HVAC system was run continuously while the school was occupied. For a permanent solution, subslab depressurization points were installed in phases in both the basement and on the first floor. Due to the high radon levels and complex foundation, it was anticipated that several suction points would be needed.

A 1-ft-diameter subslab suction pit was installed in the basement with a 4-in.-diameter pipe. Radon reduction was about 50 percent, with the subslab pressure field extending less than 30 ft. The suction pit was excavated to a diameter of about 3 ft, with an additional decrease in radon levels and an increase in pressure field extension. The suction fan was replaced with a larger fan, resulting in additional reductions in radon levels. This also increased pressure field extension to 40 ft. This basement suction point also caused some measurable depressurization under the first floor slab, indicating some air flow between the slabs.

To evaluate the effectiveness of the single-point subslab suction system in this school and to investigate the effects of the single-fan HVAC system on mitigation performance, *Figure 2* shows radon and pressure measurements in the school over a 10-day period in June 1988.

The first-floor single-fan HVAC system was operated continuously during



Figure 2. Radon and pressure measurements over a 10-day period in Case Study B.

the school week to reduce radon levels while the school was in session on the first floor. Since the basement was unoccupied during the monitoring period, the basement HVAC system was not operated.

Over the weekend (day 156), the HVAC system and the single-point subslab suction system on the first floor were turned off, and the radon levels rose quickly to more than 70 pCi/L on the first floor and 140 pCi/L in the basement.

On day 157, the subslab suction system remained off, but the first-floor HVAC system was turned on. Radon levels on both floors dropped and the differential pressure under the slab and within the block wall became slightly negative relative to the room. On days 158-163, both the HVAC system and subslab suction system were operating and radon levels remained low.

On days 164 and 165, the subslab suction system was operated and the first-floor HVAC system was off. This increased first-floor radon levels to 40 pCi/L, indicating that one suction point was not adequate if the HVAC system was not operating.

To ensure acceptable radon levels on the first floor while the HVAC system was not in operation, another suction point with a 3-ft-diameter suction pit was installed on the first floor. Addition of this suction point reduced levels on the first floor, although radon levels on both floors still rose above 10 pCi/L at night with the HVAC system off.

Pressure field extension measurements made with these two suction points operating indicated incomplete coverage of both floors. Consequently, two additional suction points with 1-ft-diameter suction pits were installed in the basement, and a fifth suction point with a 1-ft-diameter suction pit was installed on the first floor.

Nine pressure field extension measurements showed overlapping fields between suction points in the basement area, indicating that all of the basement sub-slab was adequately depressurized. Basement radon levels measured less than 2 pCi/L with the air handlers off and the mitigation systems operating; however, first-floor radon levels still rose above 4 pCi/L at night with the air handlers off.

Based on mapping of subslab radon levels in more than 20 test holes on the first floor, three additional suction points were installed, each with a 6-in.-diameter pipe and a 1-ft-diameter subslab suction pit. Two points were manifolded to a single fan, and a separate fan was installed on the other suction point.

After installation of these last three suction points, radon levels stayed below 4 pCi/L on both floors, except for occasional brief excursions at night. A larger fan was installed, and this appears to be reducing radon levels satisfactorily. More than 10 pressure field extension measurements made on the first floor showed little short-term variation when the first-floor HVAC system was turned off. This indicates that the present system is achieving adequate coverage even when the HVAC fan is not operating.

Although subslab suction was effective in solving a serious radon problem at this school, it was surprising that it took eight suction points. Aggregate under the slab was confirmed visually at every suction point; however, the aggregate used was probably unscreened "crusher run," containing a great deal of fines. This tends to confirm the belief that screened, coarse aggregate (0.75 to 1.25 in., essentially free of any material less than 0.25 in. diameter) is preferred for optimal operation of subslab depressurization systems.

Case Study C

This school building is slab-on-grade with block walls and no utilities below grade except sanitary sewers. The original building was constructed in 1956 and has four area air handlers for heating and ventilating with a central boiler room. A classroom wing was added in 1968 and unit ventilators are in each room. None of the building is air-conditioned. Construction plans specified 4 in. of subslab aggregate under the entire building.

Elevated radon levels were found in the locker rooms on each side of the gymnasium in the original building and in the new classroom wing. Mitigation of each of these areas is discussed as follows.

Original building locker room mitigation. Although the locker rooms and gymnasium are on the same air handler, the gymnasium measured 2 pCi/L; the girls' locker room, 5 to 6 pCi/L; and the boys' locker room, 5 to 19 pCi/L. Further examination indicated that each locker room area had large exhaust fans to remove odors and shower steam.

Differential pressure measurements (using a micromanometer) with the air handler and exhaust fans operating correlated, with the radon levels showing that the gymnasium was slightly positive, the girls' locker room area slightly negative, and the boys' locker room area significantly negative.

Construction plans showed that each locker room area was a continuous slab over aggregate. As a result, a subslab suction point, using a 6-in. pipe, was placed in each locker room area with a 1-ft-diameter suction pit. Both locker room areas measured less than 4 pCi/L with the exhaust fans and the subslab depressurization systems operating, indicating that the subslab suction systems effectively overcame the negative pressures caused by the exhaust fans.

New classroom wing. Weekend charcoal canister measurements were made in April 1988 in this wing with the unit ventilators off. All but one room measured above 4 pCi/L; a room in the northeast corner measured 27 pCi/L. Levels decreased from north to south in this wing, as did subslab radon levels.

A CRM was placed in the room with the highest radon levels. When the unit ventilator was off, levels above 20 pCi/L were reached nightly but remained below 2 pCi/L when the unit ventilator was run continuously. Pressure measurements with a micromanometer confirmed that the unit ventilator was pressurizing the room slightly.

Since the unit ventilators are off at night (except in extremely cold weather when they are cycled), it was decided to install two subslab depressurization points in the wing. These 4-in.-diameter suction pipes were installed in the hall and manifolded with an above-ceiling 6-in.-diameter pipe running to a fan at the north end of the building. One suction point was installed with a 3-ft-diameter suction pit about 20 ft from the east end of the hall. The other suction point was installed with a 1-ft-diameter suction pit about 40 ft west of the first point. Pressure field extension measurements indicated that the two fields overlapped, and all of the wing was depressurized to the outside walls except for the southernmost classrooms.

Since the pressure field extension around the 1-ft-diameter suction pit was not as great as around the 3-ft-diameter suction pit, the 1-ft-diameter suction pit was increased to 3 ft in diameter. This extended the measurable depressurization area by 10 ft to the south (enough to reach the last two classrooms) and almost doubled the amount of depressurization in the test holes in all directions around the suction point. With the subslab depressurization system operating and the unit ventilator fans off, radon levels were less than 4 pCi/L in all classrooms.

Case Study D

The original building of this school was built in 1958 and is heated with hot water radiant heat in the slab. In 1978, a kindergarten room was added to the original building and a separate building (referred to as Building B) was built. Building B contains four classrooms, a library, a teachers' workroom, a conference room and restrooms.

The kindergarten room is heated

with hot water radiant heat, and Building B is heated with unit ventilators. Office space in the original building is air conditioned with a window unit. No other area of either building is air conditioned.

The original building has two 3,600 cfm roof-mounted fans that could be used to exhaust air in plenums over the hall ceiling. Each room has a ceiling vent connecting to these hall plenums. However, the exhaust fans are never used, so the building has no active ventilation system. Plans showed that the original building had 6 in. of aggregate under a 6-in.-thick slab (containing hot water pipes) and Building B had 4 in. of aggregate under a 4-in. slab.

All rooms in both buildings were tested with charcoal canisters over a weekend in mid-April 1988. The eight rooms in Building B measured between 17 and 20 pCi/L. It is believed that the unit ventilators were off during the testing weekend, but this could not be confirmed. Seven tests in the classrooms, library and multi-purpose room in the original building measured between 12 and 23 pCi/L. Mitigation of the two buildings is discussed as follows.

Building B (unit ventilators). A CRM was placed in one of the classrooms in Building B to measure the effects of unit ventilator operation on radon entry. It was found that radon levels would rise overnight to more than 20 pCi/L with the ventilator off, but would remain below 2 pCi/L with the ventilators on. Again, this shows that this type of ventilator can pressurize the room slightly, preventing radon entry when run continuously.

Since the ventilators are off during night setback, a four-point subslab depressurization system was installed. Four 4-in.-diameter pipes were connected to two 6-in.-diameter manifold pipes above the drop ceiling with a common suction fan. (Two vertical pipes are manifolded to each overhead pipe.) Pressure field extension measurements indicated that depressurization extended 50 ft, the minimum distance necessary to reach all parts of the slab.

With the subslab system operating and the unit ventilators off, all rooms remained below 4 pCi/L. However, based on the pressure field extension measurements, the system may be marginal during cold weather. If radon levels rise above 4 pCi/L, it is believed that subslab depressurization can be improved by sealing the floor-to-wall opening. Expansion joints (0.25 in. in width) around all of the slabs in the building are deteriorating, leaving significant openings to the subslab. This probably leads to some short-circuiting of the subslab depressurization system.

Original building (intra-slab radiant heat). Subslab suction on this intra-slab radiant-heated building was a challenge since construction plans showed that the hot water pipes in the slab were 15 in. or less apart over the entire building. As a result, it was difficult to locate an area where a 6-in. subslab suction point could be placed without damaging a hot water pipe. A 3 sq ft area without water pipes was finally located in each room. A hole was successfully cut through one of these areas.

The plans indicated that the aggregate was a minimum of 6 in. deep, much deeper than at any other school examined. A 6-in.-diameter suction pipe was installed with a 3-ft-diameter pit. Pressure field extension was far greater than expected, and depressurization could be measured as far as 90 ft from the suction hole.

These results were surprising since the aggregate appeared to be some type of "crusher run" aggregate with a certain amount of fines. However, in leveling the aggregate before pouring the concrete, it is probable that most of the fines sifted to the lower portion of the aggregate bed, leaving a fairly thick area of large-diameter aggregate immediately under the



Figure 3. Radon, pressure and temperature measurements over 5-day period in Case Study D.

concrete. It is believed that this layer of coarse stone made for a much greater pressure field extension and will be studied further. Preliminary follow-up tests indicate that this one suction point will solve the radon problem in the original building.

To analyze the effectiveness of a single-point subslab suction system and to investigate the pressures that control radon levels in schools during hot weather, radon, pressure and temperature were monitored continuously in one classroom, as shown in *Figure 3*. The classrooms were kept closed during this period of very hot weather, and there is no ventilation system in this building.

When the subslab suction system was turned off from days 222-225 (July 1988), the radon levels quickly rose and followed a diurnal cycle that seems to match the temperature cycle. When the outdoor temperature was coolest relative to indoor temperature, the radon levels were highest. This can be expected from the stack effect, as discussed in Case Study B. Although a small positive pressure was measured across the slab during this period, it does not show significant diurnal variation. The differential pressure across an outside classroom wall does not show much correlation with the radon levels, except for a sharp dip in the middle of day 224 that may be due to wind.

Kindergarten room. Since the kindergarten room is an addition, the subslab area does not communicate with the original building. Consequently, a suction point was put in a closet adjacent to a restroom where the hot water pipes were spaced 24 in. apart to clear the sewer line of the commode. This suction point lowered radon levels to less than 2 pCi/L. No pressure field extension measurements were made for fear of damaging a heating water pipe.

Preliminary findings

The following preliminary conclusions can be drawn from the EPA's experience in assisting in the installation of radon mitigation systems in Maryland, Virginia, Tennessee and North Carolina schools. These conclusions are based on limited studies and will be verified and expanded with further research.

1. One of the most significant factors contributing to elevated levels of radon in schools and influencing the mitigation approach is the design and operation of the HVAC system. The complexities of large building HVAC systems present problems not previously encountered in house mitigation.

2. Pressure control through continuous HVAC fan operation can often be an effective, temporary solution to reduce elevated radon levels in schools, depending on HVAC system design. Whether such a technique is a feasible long-term solution depends on factors such as the proper operation of the system by maintenance personnel, variations in outside environmental conditions, and any additional maintenance costs and energy penalties associated with increased operation of the HVAC system.

3. A subslab depressurization system can usually overcome negative pressures induced by HVAC operation in schools if there are no return air ducts under the slabs. As with houses, subslab depressurization is more successful (and requires fewer suction points) when the slab is poured over clean, coarse aggregate.

4. Effective mitigation of schools using subslab depressurization requires greater fan capacities and suction pipe diameters than does mitigation of houses. The capacities of the fans used in these school installations were typically at least 300 cfm (at 0.75 in. WC) compared to capacities of about 150 cfm (at 0.75 in. WC) for fans commonly installed in house subslab depressurization systems. Suction pipe diameters of 4 to 6 in. often proved successful in these installations, compared to pipe diameters of 4 in. or less typically used in houses.

Acknowledgments

The authors would like to thank all of the school personnel who contributed to the information presented in this paper.

NOTICE

This document has been reviewed in accordance with U.S. Environmental Protection Agency policy and approved for publication. Mention of trade names or commercial products does not constitute endorsement or recommendation for use.

This article documents research that was conducted under the auspices of the U.S. Environmental Protection Agency (USEPA). As an arm of the government, the USEPA has a paid up, non-exclusive, irrevocable, worldwide license to reproduce, prepare derivative works, and distribute to the public all of the material contained herein, and to grant others acting on its behalf the right to do so. The USEPA grants to the National Technical Information Service, Department of Commerce, the right to act as its agent in the distribution of this material.

ROUTING AND TRANSMITTAL SLIP Date 2/21/90

TO: (Name, office symbol, room number, building, Agency/Post)	Initials	Date
1. US EPA, CERI (G-74) DOCUMENT TRACKING COORD. 2. CINCINNATI, OH 45268		
3.		
(Re: AEERL-P-595 for NTIS) 4.		
5. (AEERL Author: A. Craig)		

X	Action		File		Note and Return
	Approval		For Clearance		Per Conversation
	As Requested		For Correction		Prepare Reply
	Circulate		For Your Information		See Me
	Comment		Investigate		Signature
	Coordination		Justify		

REMARKS

1. **Please process the attached for input to NTIS.**
2. **Attachment includes:**
   (a) Published paper (2 cc).
   (b) Technical Report Data Form 2220-1 (2 cc).
   (c) EPA-362 (1 cc)
3. **Please notify the undersigned when NTIS number is assigned.**
4. NOTE: Part I of this two-part article was sent to you 1/23/90 (AEERL-P-594).

DO NOT use this form as a RECORD of approvals, concurrences, disposals, clearances, and similar actions

FROM: (Name, org. symbol, Agency/Post)	Room No.—Bldg.
W.W. Whelan, TM, MD-64 EPA, AEERL, RTP, NC 27711	Phone No. 629-2218

5041-102

OPTIONAL FORM 41 (Rev. 7-76)
Prescribed by GSA
FPMR (41 CFR) 101-11.206 4/17/89

* GPO : 1981 O - 361-529 (346)